

BIOFICIENT PE 1 - DECLARATION OF PERFORMANCE

kingspan-klargester-bioficient-PRO-1-dop-en-jul2026-v1

1.Unique identification code of the product-type:

**Wastewater Treatment Plant for 6 Population Equivalents
BioFicient PE 1**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**BioFicient Prefabricated Domestic Wastewater Treatment Plant: See CE marking affixed to product
BioFicient PE 1 (6PE)**

3. Intended use/es of the product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

To be used for Collection & Treatment of Wastewater from Domestic applications up to 50 Population Equivalent

4. Manufacturer name, registered trade name or registered trade mark and contact address as required under Article 11(5):

**Kingspan Water & Energy Ltd
College Rd North
Aston Clinton, Aylesbury, Buckinghamshire
HP22 5EW**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System/s of assessment and verification of constancy of performance (AVCP) of the product as set out in CPR, Annex V:

3

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

EN:12566-3:2005+A2:2013

Notified body/ bodies:

Notified Body No: 1739 + PIA Prüfinstitut für Abwassertechnik GmbH

Document date:	Document version no:	ECN no:
17/07/2026	V1	2369




8. Declared performance/s:

Essential characteristics		Performance		Harmonised technical specification
Structural Behaviour		Confirmed by Pit Test under the following Conditions: - Maximum installation Depth 0m over cover level - Wet conditions maximum water level 1.88m		EN:12566-3:2005+A2:2013
Reaction to fire		Class F		
Water Tightness (water test)		Water Tight (water test)		
Material Durability		MFR (230/2,16) = (4,0± 3,0g)/10 min (EN ISO 1133)		
		Density ≥ 930 kg/m³ (EN ISO 1133)		
		Tensile Strength	At Yield (50mm/min) 21MPa	
			At Break (50mm/min) 21MPa	
Treatment Efficiency	COD	90.6%	67 mg/l	
	BOD ₅	94.4%	20 mg/l	
	NH ₄ -N	99.0%	0.4 mg/l	
	SS	92.7%	27 mg/l	
	P	NPD	NPD	
	KN	NPD	NPD	
Electrical Consumption (measured during 38 week test)		0.52 kWh/d		
Emission of Dangerous Substances		NPD		

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



David Anderson – Water Business Unit Director

At Portadown on 16 July 2026

Document date:	Document version no:	ECN no:
17/07/2026	V1	2369