

NS PLASTIC BYPASS SEPARATORS - DECLARATION OF PERFORMANCE

kingspan-klargester-nsbp-003-006-dop-en-oct2021-v1

1. Unique identification code of the product-type:

**Separator Systems for Light Liquids, Plastic Construction
NSBP003, NSBP004 & NSBP006**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**Serial Number/Works Order Number printed on the Product Information Label
& affixed to product**

3. Intended use/es of the product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

To be used for Collection & Separation of Light Liquids from Wastewater by means of gravity and/or coalescence

4. Manufacturer name, registered trade name or registered trade mark and contact address as required under Article 11(5):

**Kingspan Water & Energy Ltd
College Rd North
Aston Clinton, Aylesbury, Buckinghamshire
HP22 5EW**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System/s of assessment and verification of constancy of performance (AVCP) of the product as set out in CPR, Annex V:

4

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

EN:858-1:2002

Notified body/ bodies:

Notified Body No: 1739 + PIA Prüfinstitut für Abwassertechnik GmbH

Document date:	Document version no:	ECN no:
12/10/2021	V1.	1587



8. Declared performance/s:

Essential characteristics		Performance			Harmonised technical specification
Crushing Resistance (vertical load test)		Pass (also wet conditions)			EN:858-1:2002
Structural Behaviour		Pass			
Reaction to fire		Class E			
Water Tightness (water test)		Pass			
Material Durability		MFR (190/2,16) = 3.0± 1g/10 min (ISO 1133)			
		Density ≥ 930 kg/m³ (ISO 1872)			
		Yield Stress ≥ 19 Mpa (ISO 527-2)			
		Pressure A1 = 1 (EN1778)			
		Pressure A2K = 1 (EN1778)			
Treatment Efficiency	Sample	Specified Maximum Light Liquid (mg/l)	Actual Light Liquid (mg/l)		
	1	≤10	0.37	Pass	
	2	≤10	0.22	Pass	
	3	≤10	0.35	Pass	
	4	≤10	0.23	Pass	
	5	≤10	0.35	Pass	
	Average	≤5	0.30	Pass	
Electrical Consumption		n/a			

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



David Anderson – Water Business Unit Director

At Portadown on 22 September 2021

Document date:	Document version no:	ECN no:
12/10/2021	V1.	1587